

# CERTIFICATE

Issued to:  
Applicant:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Road, Wugu District  
248 New Taipei City, Taiwan

Licensee:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Road, Wugu District  
248 New Taipei City, Taiwan

Product : Independent LED controlgears  
Trade name(s) : MEAN WELL  
Type(s)/model(s) : LPF-90x-y

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014 and EN 61347-2-13:2014/A1:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2175773

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 28 March 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-103242

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



Henk Schendstok  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Independent LED controlgears
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: LPF-90-15, LPF-90-20, LPF-90-24, LPF-90-30, LPF-90-36, LPF-90-42, LPF-90-48, LPF-90-54, LPF-90D-15, LPF-90D-20, LPF-90D-24, LPF-90D-30, LPF-90D-36, LPF-90D-42, LPF-90D-48 and LPF-90D-54
Rated input voltage	: 100-240 V~
Rated input current	: 0,95 A
Rated frequency	: 50/60 Hz
Power factor	: 0,95
Max. case temperature (tc)	: 70 °C
Ambient temperature (ta)	: 40 °C
Class of insulation	: Class II
Degree of protection	: IP67
Description	: Constant voltage mode Thermal, short-circuit and overload protection With MM signs

**Product data – type LPF-90D-15 and LPF-90-15**

Output voltage	: 15 Vdc
Output current	: 5,0 A
Rated output power	: 75 W

**Product data – type LPF-90D-20 and LPF-90-20**

Output voltage	: 20 Vdc
Output current	: 4,5 A
Rated output power	: 90 W

**Product data – type LPF-90D-24 and LPF-90-24**

Output voltage	: 24 Vdc
Output current	: 3,75 A
Rated output power	: 90 W

**Product data – type LPF-90D-30 and LPF-90-30**

Output voltage	: 30 Vdc
Output current	: 3,0 A
Rated output power	: 90 W

**Product data – type LPF-90D-36 and LPF-90-36**

Output voltage	: 36 Vdc
Output current	: 2,5 A
Rated output power	: 90 W

**Product data – type LPF-90D-42 and LPF-90-42**

Output voltage	: 42 Vdc
Output current	: 2,15 A
Rated output power	: 90,3 W

**Product data – type LPF-90D-48 and LPF-90-48**

Output voltage : 48 Vdc  
Output current : 1,88 A  
Rated output power : 90,24 W

**Product data – type LPF-90D-54 and LPF-90-54**

Output voltage : 54 Vdc  
Output current : 1,67 A  
Rated output power : 90,18 W

**TESTS****Test requirements**

EN 61347-1:2015  
EN 61347-2-13:2014  
EN 61347-2-13:2014/A1:2017

**Test result**

The test results are laid down in DEKRA test file 434292900.

**Additional information**

Detailed models description:

LPF-90x-y:

The “x” in the model name can be D or blank to denote with dimming function (D) or without (blank); the “y” in the model name can be 15, 20, 24, 30, 36, 42, 48 or 54 to denote output voltage in volt.

The product also considers EN 62384:2006 + A1:2009

The list of components is laid down at test report 4342929.50.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

MEAN WELL (Guangzhou) Electronics Co.,Ltd. Huadu Branch  
No.11 Jingu South Road, Huadong Town, Huadu District,  
Guangzhou City, Guangdong Province, China

Trade name(s) : MEAN WELL stands for

