




**BUREAU  
VERITAS**

## ATTESTATION of conformity with European Directives



Attestation Number: 2188AB10181001  
Product: Switching power supplies  
Brand Name: MEAN WELL  
Model: UHP-1500-xy( x=115, 230, 380; y=Blank, PM, CAN ),  
UHP-1500-380E  
Additional Models: See report item 2.1  
Applicant: MEAN WELL Enterprises Co., Ltd.  
Address: No. 28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891,  
Taiwan Taiwan  
Technical Characteristics: INPUT: 100-120Vac 11.0A  
200-240Vac 8.0A 50/60Hz

The submitted sample of the above equipment has been tested for  marking according to following European Directive and standards:

- Electromagnetic Compatibility Directive 2014/30/EU

Standards	Report Number	Report date
EN 55032:2015+A1:2020,CLASS A EN IEC 61000-3-2:2019 EN 61000-3-3:2013+A1:2019 EN 55035:2017+A11:2020	CE2110WDG0181	Jan. 21, 2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The  marking may be affixed if all relevant and effective European Directives with  are applicable.

Assistant Manager  
EMC Department



Name: Madison Luo  
Date: Jan. 21, 2022

This document shall not be reproduced, except in full, without the written approval of  
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.

Information given in this document is related to the tested specimen of the described electrical sample.