



UK Declaration of Conformity

For the following equipment:

Product Name: Variable Frequency Drive

Model Designation: VFD-350C-230

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic

Equipment Regulations 2012: SI 2012 No. 3032

Electrical Equipment (Safety) Regulations 2016:

TUV certificate No: R50603672 BS EN 61800-5-1:2007+A1+A11

Electrical Compatibility Regulations 2016:

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	BS EN IEC 61800-3:2018	Class A
Harmonic current	BS EN IEC 61800-3:2018	Class A
Voltage flicker	BS EN IEC 61800-3:2018	Clause 5

voltage more	DO EN 120 01000 0.2010	Gladoo o
EMS (Electro-Magnetic S	usceptibility)	
BS EN IEC 61800-3:2018		
ESD air	BS EN 61000-4-2:2009	Level 3 8KV
ESD contact	BS EN 61000-4-2:2009	Level 2 4KV
DE C. L. C. C. C.	DO EN IEO 04000 4 0 0000	10V/m(80MHz-1.0GHz) 3V/m(1.4GHz-2.0GHz)
RF field susceptibility	BS EN IEC 61000-4-3:2020	Level 3 1V/m(2.0GHz-2.7GHz)
EFT bursts	BS EN 61000-4-4:2012	Level 3 2KV/5KHz
Surge susceptibility	EN 61000-4-5:2014+A1:2017	Level 3 1KV/Line-Line
Surge susceptibility	EN 61000-4-5:2014+A1:2017	Level 3 2KV/Line-Earth
Conducted susceptibility	BS EN 61000-4-6:2014	Level 3 10V
Magnetic field immunity	BS EN 61000-4-8:2010	Level 4 30A/m
Voltage dip, interruption	EN IEC 61000-4-11:2020	0% residual voltage for 0.5 cycles, 0% residual voltage for 1 cycles, 70% residual voltage for 2 cycles, 0% residual voltage for 250 cycles
Voltage deviation	IEC 61000-2-4 Class 2	-15% Un +10% Un
Total Harmonic distortion (THD) Individual Harmonic orders	IEC 61000-2-4 Class 3 IEC 61000-4-13 Class 3	THD 12 %
Frequency variations	IEC 61000-2-4	±4%
Frequency rate of change	IEC 61800-3:2018	2%/s

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Regulations on the complete system again.

(Name / Position)

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC3xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Signature)

(Manufacturer Address)

Taiwan

Aries Jian/ Director, Group R&D: (Name / Position)

Oct. 20th, 2023

(Place) (Date) Alex Tsai/ Director, Product Strategy Center: (Signature)